



FIRST FLOOR PLAN AREA: 2203 SQ. FT.

LOGS TO BE 13"-14" AVERAGE DIAMETER
WESTERN RED CEDAR W/ 12" GAIN PER ROUND
SECOND FLOOR SYSTEM TO BE:
3/4" T&G PLYWOOD SUBFLOOR
2X8 @ 16" O.C FLR. JST.
W/ X-BRIDGING @ 7'-0" O.C

GENERAL NOTES:

ALL DIMENSIONS ARE CONSTRUCTION DIMENSIONS.
ALL DIMENSIONS TO BE VERIFIED ON SITE BY GEN. CONTRACTOR.
THIS BUILDING WAS DESIGNED IN ACCORDANCE WITH
THE UNIFORM BUILDING CODE 1997

ALL LOG SIZES NOTED TO BE MID SPAN DIAMETERS.
ALL LOG WALL AND LOG HEIGHTS INDICATED ON PLAN ARE MINIMUM HGT.
5/8" DIA. THREADED STEEL THRU BOLT
FROM BOTTOM OF BASE LOG TO TOP
OF CAP LOG C/W 5/8" NUT &
TIMBER WASHER EACH END
AS PER LOG MANUFACTURER THRU BOLT PLAN

TOW= TOP OF LOG WALL
TOW= 0 @ TOP OF SUBFLOOR
(1ST FLOOR FRAMING SYSTEM)
T= TOP OF LOG
B= BOTTOM OF LOG

LOG STAIRS MUST BE RECALCULATED
BY STAIRS BUILDER AFTER
ACTUAL TOTAL RISE IS KNOWN