



**FIRST FLOOR PLAN AREA: 2203 SQ. FT.**

LOGS TO BE 13"-14" AVERAGE DIAMETER  
WESTERN RED CEDAR W/ 12" GAIN PER ROUND  
SECOND FLOOR SYSTEM TO BE:  
3/4" T&G PLYWOOD SUBFLOOR  
2X8 @ 16" O.C FLR. JST.  
W/ X-BRIDGING @ 7'-0" O.C

**GENERAL NOTES:**

ALL DIMENSIONS ARE CONSTRUCTION DIMENSIONS.  
ALL DIMENSIONS TO BE VERIFIED ON SITE BY GEN. CONTRACTOR.  
THIS BUILDING WAS DESIGNED IN ACCORDANCE WITH  
THE UNIFORM BUILDING CODE 1997

ALL LOG SIZES NOTED TO BE MID SPAN DIAMETERS.  
ALL LOG WALL AND LOG HEIGHTS INDICATED ON PLAN ARE MINIMUM HGT.  
5/8" DIA. THREADED STEEL THRU BOLT  
FROM BOTTOM OF BASE LOG TO TOP  
OF CAP LOG C/W 5/8" NUT &  
TIMBER WASHER EACH END  
AS PER LOG MANUFACTURER THRU BOLT PLAN

TOW= TOP OF LOG WALL  
TOW= 0 @ TOP OF SUBFLOOR  
(1ST FLOOR FRAMING SYSTEM)  
T= TOP OF LOG  
B= BOTTOM OF LOG

LOG STAIRS MUST BE RECALCULATED  
BY STAIRS BUILDER AFTER  
ACTUAL TOTAL RISE IS KNOWN